



# CHARITON RESEARCH INSTITUTE PRIVATE LIMITED

(ISO:9001, ISO:45001 & ISO:14001 CERTIFIED LABORATORY)

No.67/3, 1st Floor, Industrial Suburb, Yeshwanthpur, BANGALORE - 560 022. INDIA

## TEST CERTIFICATE


### TEST REPORT

FORMAT NO: CRI/7.8/F/01

Name & Address of the Customer	M/s. JCPRO ACADEMY No. 6, Ittgallpura Village, Rajankunt Post, Yelahanka, Banaglore - 560064.	Job Order No: CRIPL2024-25/04/0004
		Report No: CRI/24-25/0110
		Group: Water
		Product: Water
Date of sample Collection	08.05.2024	Sample Details: Drinking Water
Date of Sample Receipt	08.05.2024	Sampling Details
Duration of Test	08.05.2024 - 15.05.2024	Method: IS 3025 (Part-01)
Sample Collected by	CRI Representative	Type: Grab Sample
		Date of Report: 15.05.2024
		Sample Condition: Satisfactory

Sl. No.	Parameters	Units	Results	Limits as per IS 10500		Test method
				Acceptable Limits	Permissible Limits	
1.	pH @ 25°C	---	7.12	6.5 - 8.5	No Relaxation	IS:3025(Part-11)
2.	Odour	--	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5)
3.	Turbidity	NTU	<1	1	5	IS:3025(Part-10)
4.	Total Dissolved solids	mg/l	62	500	2000	IS:3025(Part-16)
5.	Conductivity	µS/cm	113	Not Specified	Not Specified	IS:3025(Part-14)
6.	Alkalinity as CaCO <sub>3</sub>	mg/l	28	200	600	IS:3025(Part-23)
7.	Hardness as CaCO <sub>3</sub>	mg/l	20	200	600	5 of IS:3025(Part-21)
8.	Calcium as Ca	mg/l	6.4	75	200	5 of IS:3025(Part-40)
9.	Magnesium as Mg	mg/l	<2.0	30	100	6 of IS:3025(Part-46)
10.	Chloride as Cl	mg/l	14.99	250	1000	2 of IS:3025(Part-32)
11.	Sulphate as SO <sub>4</sub>	mg/l	6.55	200	400	4 of IS:3025(Part-24)
12.	Iron as Fe	mg/l	<0.1	1.0	No Relaxation	7 of IS-3025 (Part-53)
13.	Fluoride as F	mg/l	0.52	1	1.5	APHA 23 <sup>rd</sup> Edition 4500F D
14.	Nitrate as NO <sub>3</sub>	mg/l	<0.1	45	No Relaxation	3 of IS:3025(Part-34)
15.	Ammonia as NH <sub>3</sub>	mg/l	<0.1	0.5	No Relaxation	2.3 of IS:3025(Part-34)

-----End of Report-----

  
Authorized Signatory  
V. Chandra Sekhar  
Technical Manager

Page 01 of 01



Terms & Condition Over Leaf

Tel.:080-23479296 Fax : 23479721 Mob : 9448000637 / 9845015964  
E-mail : Kumar@charitonindia.com / marketing@charitonindia.com Web : www.charitonindia.com  
CIN: U73200KA2020PTC134050 GST NO: 29AAICC7110NIZC



# CHARITON RESEARCH INSTITUTE PRIVATE LIMITED

(ISO:9001, ISO:45001 & ISO:14001 CERTIFIED LABORATORY )

No.67/3, 1st Floor, Industrial Suburb, Yeshwanthpur, BANGALORE - 560 022. INDIA


## TEST CERTIFICATE

### TEST REPORT

FORMAT NO: CRI/7.8/F/01

Name & Address of the Customer	M/s. JCPRO ACADEMY No. 6, Ittgallpura Village, Rajankunt Post, Yelahanka, Banaglore – 560064.	Job Order No: CRIPL2024-25/04/0004
		Report No: CRI/24-25/0110
		Group: Water
		Product: Water
Date of sample Collection	08.05.2024	Sample Details: Drinking Water
Date of Sample Receipt	08.05.2024	Sampling Details
Duration of Test	08.05.2024 – 10.05.2024	Method: IS 3025 (Part-01)
Sample Collected by	CRI Representative	Type: Grab Sample
		Date of Report: 15.05.2024
		Sample Condition: Satisfactory

Sl. No.	Parameters	Results	Limits as per IS 10500	Test method
1.	Coliforms, per 100ml	Absent	Shall not be detectable in any 100 ml sample	IS 15185
2.	E. Coli, per 100ml	Absent	Shall not be detectable in any 100 ml sample	IS 15185

  
15/05/2024  
Authorized Signatory  
Dr. Kumar A  
Technical Manager

-----End of Report-----

Page 01 of 01



Terms & Condition Over Leaf

Tel.:080-23479296 Fax : 23479721 Mob : 9448000637 / 9845015964  
E-mail : Kumar@charitonindia.com / marketing@charitonindia.com Web : www.charitonindia.com  
CIN: U73200KA2020PTC134050 GST NO: 29AAICC7110NIZC